

GMI G102 20 Kw Generator Temperature Rise Test

Rating = 30 Kw @ 185 Rpm

Date =	02/02/10
Amb Air =	25.0 Deg C
Test By =	Paul Lillington
Air Flow =	6 M/sec (to replicate real world wind turbine conditions)
Enclosure =	IP55

Read No	Run Time Hours	Run Time (min)	Power Out (Watts)	Amps	RMS Volts	Inner Stator Temperature	Outer Stator Temperature	Case Temperature
1	0	0.00	30,037.92	82.35	210.60	25.00	25.00	25.00
2	0.25	15.00	30,081.38	83.50	208.00	58.00	50.00	45.00
3	0.5	30.00	30,535.02	84.80	207.90	73.00	64.00	59.00
4	0.75	45.00	30,539.87	85.10	207.20	85.00	72.00	67.00
5	1	60.00	30,505.72	85.50	206.00	92.30	76.00	71.00
6	1.25	75.00	30,584.65	86.35	204.50	95.50	80.00	75.00
7	1.5	90.00	30,791.44	87.49	203.20	96.00	80.50	75.50
8	1.75	105.00	30,744.63	87.40	203.10	96.80	81.00	76.00
9	2	120.00	30,658.13	87.24	202.90	97.70	81.60	76.60
10	2.25	135.00	30,658.13	87.24	202.90	98.00	82.00	77.00
11	2.5	150.00	30,658.13	87.24	202.90	98.10	82.00	77.00
12	2.75	165.00	30,658.13	87.24	202.90	98.00	82.00	77.00
13	3	180.00	30,658.13	87.24	202.90	98.20	82.00	77.00
14	3.25	195.00	30,658.13	87.24	202.90	98.10	82.00	77.00
15	3.5	210.00	30,658.13	87.24	202.90	98.20	82.00	77.00
16	3.75	225.00	30,658.13	87.24	202.90	98.30	82.00	77.00
17	4	240.00	30,658.13	87.24	202.90	98.20	82.00	77.00
18	4.25	255.00	30,679.21	87.30	202.90	98.10	82.00	77.00
19	4.5	270.00	30,679.21	87.30	202.90	98.30	82.00	77.00
20	4.75	285.00	30,679.21	87.30	202.90	98.20	82.00	77.00
21	5	300.00	30,679.21	87.30	202.90	98.20	82.00	77.00
22	5.25	315.00	30,679.21	87.30	202.90	98.30	82.00	77.00
23	5.5	330.00	30,679.21	87.30	202.90	98.20	82.00	77.00
24	5.75	345.00	30,679.21	87.30	202.90	98.30	82.00	77.00
25	6	360.00	30,679.21	87.30	202.90	98.30	82.00	77.00



